

**Report date:** 21st April 2008

**Table:** Average water quality for Kampala during the period of 14<sup>th</sup> -20<sup>th</sup> April 2008

Parameter	Monitoring points								National Standard for potable water quality
	Unit	Raw water	Treated Water	Water in Supply					
				Rubaga Division	Nakawa Division	Makindye Division	Kampala Central	Kawempe Division	
pH	...	8.45	7.4	6.94	6.77	6.88	6.97	6.78	<b>6.5- 8.5</b>
Turbidity	NTU	16.2	1.18	0.30	0.22	0.26	0.18	0.43	<b>≤ 5.00</b>
Colour	PTU	148	5	6	3	4	2	9	<b>≤ 15</b>
Free chlorine	mg/l	NA	1.45	0.35	0.3	0.4	0.35	0.3	<b>≥0.20</b>
E-Coli	CFU/100 ml	36	0	0	0	0	0	0	<b>0</b>
Faecal -Strepstococi	CFU/ 100 ml	24	0	0	0	0	0	0	<b>0</b>

NA: Not applicable