

Report date: 28<sup>th</sup> April 2008

Table: Average water quality for Kampala during the period of 21<sup>st</sup> -27<sup>th</sup> April 2008

Parameter	Monitoring points								National Standard for potable water quality
	Unit	Raw water	Treated Water	Water in Supply					
				Rubaga Division	Nakawa Division	Makindye Division	Kampala Central	Kawempe Division	
pH	...	8.12	7.32	7.12	6.95	7.08	6.95	6.99	6.5- 8.5
Turbidity	NTU	12.8	0.92	0.68	0.58	0.35	0.35	0.84	≤ 5.00
Colour	PTU	158	0	9	4	4	1	6	≤ 15
Free chlorine	mg/l	-	1.25	0.35	0.40	0.30	0.35	0.30	≥0.20
E-Coli	CFU/100 ml	42	0	0	0	0	0	0	0
Faecal -Streptococi	CFU/ 100 ml	24	0	0	0	0	0	0	0

NA: Not applicable