

Report date: 12th November 2007

Table: Average water quality for Kampala during the period of 5th -11th November 2007

Parameter	Monitoring points								National Standard for potable water
	Unit	Raw water	Treated Water	Water in Supply					
				Rubaga Division	Nakawa Division	Makindye Division	Kampala Central	Kawempe Division	
pH	...	7.67	7.08	6.92	6.87	6.82	7.07	6.79	6.5- 8.5
Turbidity	NTU	24.2	2.04	0.53	0.68	0.87	0.72	1.01	≤ 5.00
Colour	PTU	173	8	7	9	11	14	12	≤ 15
Free chlorine	mg/l	NA	0.92	0.30	0.25	0.25	0.20	0.35	≥0.20
E-Coli	CFU/100 ml	46	0	0	0	0	0	0	0
Faecal -Streptococi	CFU/ 100 ml	36	0	0	0	0	0	0	0

NA: Not applicable