

Report date: 12<sup>th</sup> May 2008

Table: Average water quality for Kampala during the period of 5<sup>th</sup> - 11<sup>th</sup> May 2008

Parameter	Monitoring points								National Standard for potable water quality
	Unit	Raw water	Treated Water	Water in Supply					
				Rubaga Division	Nakawa Division	Makindye Division	Kampala Central	Kawempe Division	
pH	...	7.95	7.20	6.75	6.77	7.08	6.88	6.78	6.5- 8.5
Turbidity	NTU	18.5	0.79	0.82	0.32	0.98	0.52	0.42	≤ 5.00
Colour	PTU	190	2	5	3	6	1	8	≤ 15
Free chlorine	mg/l	-	1.10	0.35	0.30	0.40	0.35	0.30	≥0.20
E-Coli	CFU/100 ml	44	0	0	0	0	0	0	0
Faecal -Strepstococi	CFU/ 100 ml	30	0	0	0	0	0	0	0

NA: Not applicable