

**Report date:** 26<sup>th</sup> January 2015

**Table:** Average water quality for Kampala during the period of 19<sup>th</sup> Jan 2015 - 25<sup>th</sup> Jan 2015

Parameter	Monitoring points								National Standard
	Unit	Raw water	Treated Water Water Works	Water in Supply					For potable water quality
				Rubaga Division	Nakawa Division	Makindye Division	Kampala Central	Kawempe Division	
pH	...	7.0	7.1	7.0	7.1	7.0	7.0	7.1	6.5- 8.5
Turbidity	NTU	16	0.36	0.28	0.33	0.30	0.20	0.40	≤5.00
Colour	PTU	192	4	3	5	4	2	5	≤15
Free chlorine	mg/l	NA	1.26	0.25	0.35	0.45	0.45	0.20	0.20-0.50
E-Coli	CFU/100 ml	26	0	0	0	0	0	0	0
Faecal -Streptococi	CFU/ 100 ml	40	0	0	0	0	0	0	0

NA: Not applicable

**Report date:** 19<sup>th</sup> January 2015

**Table:** Average water quality for Kampala during the period of 12<sup>th</sup> Jan 2015 - 18<sup>th</sup> Jan 2015

Parameter	Monitoring points								National Standard  For potable water quality
	Unit	Raw water	Treated Water Water Works	Water in Supply					
				Rubaga Division	Nakawa Division	Makindye Division	Kampala Central	Kawempe Division	
pH	...	7.1	6.8	6.8	6.7	6.7	6.8	6.9	6.5- 8.5
Turbidity	NTU	15	0.43	0.43	0.40	0.39	0.13	0.40	≤ 5.00
Colour	PTU	181	3	6	4	3	2	5	≤ 15
Free chlorine	mg/l	NA	1.35	0.30	0.45	0.50	0.60	0.25	0.20-0.50
E-Coli	CFU/100 ml	24	0	0	0	0	0	0	0
Faecal -Streptococi	CFU/ 100 ml	38	0	0	0	0	0	0	0

NA: Not applicable

**Report date:** 12<sup>th</sup> January 2015

**Table:** Average water quality for Kampala during the period of 5<sup>th</sup> - 11<sup>st</sup> Jan 2015

	Monitoring points	National
--	-------------------	----------

Parameter	Unit	Raw water	Treated Water Water Works	Water in Supply					Standard For potable water quality
				Rubaga Division	Nakawa Division	Makindye Division	Kampala Central	Kawempe Division	
pH	...	7.3	7.1	7.2	7.2	7.1	7.2	7.2	6.5- 8.5
Turbidity	NTU	17	0.26	0.41	0.32	0.30	0.29	0.33	≤ 5.00
Colour	PTU	195	3	2	6	5	1	4	≤ 15
Free chlorine	mg/l	NA	1.36	0.30	0.50	0.40	0.50	0.25	0.20-0.50
E-Coli	CFU/100 ml	24	0	0	0	0	0	0	0
Faecal -Streptococi	CFU/ 100 ml	44	0	0	0	0	0	0	0

NA: Not applicable

**Report date:** 05<sup>th</sup> January 2015

**Table:** Average water quality for Kampala during the period of 29<sup>th</sup> Dec 2014 - 04<sup>th</sup> Jan 2015

	Monitoring points				National Standard
				Water in Supply	

Parameter	Unit	Raw water	Treated Water Water Works	Rubaga Division	Nakawa Division	Makindye Division	Kampala Central	Kawempe Division	For potable water quality
pH	...	7.3	6.9	6.9	7.0	6.8	7.0	7.0	6.5- 8.5
Turbidity	NTU	16.5	0.12	0.20	0.22	0.38	0.17	0.28	≤ 5.00
Colour	PTU	187	0	3	3	4	1	2	≤15
Free chlorine	mg/l	NA	1.46	0.33	0.40	0.50	0.55	0.30	0.20-0.50
E-Coli	CFU/100 ml	29	0	0	0	0	0	0	0
Faecal -Streptococi	CFU/ 100 ml	42	0	0	0	0	0	0	0

NA: Not applicable