

Report date: 13th April 2015

Table: Average water quality for Kampala during the period of 6th - 11th April 2015

Parameter	National Standard for portable water	Monitoring Points													
		Kisenyi	City Centre	Kasubi	Kyengera	Rubaga	Buziga	Makindye	Muyenya	Mutungo	Kirinya	Mukono	Ntinda	Mulago	Naguru
pH	6.5-8.5	7.2	7.0	7.0	7.1	6.9	7.0	6.8	7	6.9	6.8	6.9	6.9	6.8	7.1
Electrical Conductivity ($\mu\text{S}/\text{cm}$)	1500	138	137	137	135	139	141	143	139	140	138	137	140	139	138
Turbidity (NTU)	5	1	1	0.81	0.67	0.96	0	0.69	0.48	0.55	0.43	0.34	0.64	0.50	0.47
Colour (PtCo)	15	10	8	11	12	9	2	9	4	11	10	11	8	11	11
Esherichia coliform (cfu/100 mL)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Feacal coliform (cfu/100 mL)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/l)	0.20 – 0.50	0.25	0.2	0.3	0.25	0.3	0.45	0.4	0.3	0.2	0.25	0.2	0.25	0.2	0.35