



**NATIONAL WATER & SEWERAGE CORPORATION**

**WATER QUALITY MANAGEMENT DEPARTMENT**

**ADJUMANI AREA**

**Report date:** 23rd June 2016

**Table:** Water quality for Selected zones in Adjumani during the week of 16th June, 2016.

Parameters	Units	Monitoring Points						National Standards for potable water quality (Water in Supply)
		Waterworks		Water in supply				
		Raw water Mokolo	Raw water Biyaya	Pakondo	Patua PSP	Police station	Molukpoda	
Codes		N586	N587	N588	N589	N590	N591	
pH		6.9	7.3	7.1	7.1	6.9	6.9	5.5-8.5
Colour	PtCo	7	6	2	1	0	2	15
Turbidity	NTU	0.42	0.21	0.35	0.42	0.18	0.38	≤15
Iron	mg/L	0.44	0.31	0.29	0.24	0.28	0.26	≤0.30
Free chlorine	mg/L	N/A	N/A	0.21	0.52	0.22	0.19	0.20-0.50
Faecal coliforms	CFU/100mL	4	8	0	0	0	0	0