



**NATIONAL WATER & SEWERAGE CORPORATION
WATER QUALITY MANAGEMENT DEPARTMENT**

ADUKU AREA

Report date: 24th February-2016

Table: Water quality for Selected zones in Aduku during the week of 18th February, 2016.

Parameter	Unit	Monitoring points						National Standards for potable water quality (water in supply)
		Waterworks		Water in Supply				
		Raw water	Aduku Reservoir	Open Space PSP	Igura PSP	Aduku Health Centre 4	Adyeda SP	
Codes		N955	N956	N957	N958	N959	N960	
pH	...	6.9	6.8	7	6.7	6.8	6.8	5.5 – 8.5
Turbidity	NTU	0.61	0.53	0.56	0.51	0.59	0.53	≤5
Colour	PtCo.	0	0	0	0	0	0	≤15
Iron	mg/L	0.055	0.055	0.061	0.051	0.058	0.055	≤0.300
Residue Aluminium	mg/L	N/A	N/A	N/A	N/A	N/A	N/A	≤0.20
Free chlorine	mg/L	N/A	0.22	0.28	0.26	0.22	0.28	0.20 – 0.50
Faecal -Coliform	CFU/ 100 mL	0	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required