



**NATIONAL WATER & SEWERAGE CORPORATION
WATER QUALITY MANAGEMENT DEPARTMENT**

APAC AREA

Report date: 24 th February-2016

Table: Water quality for Selected zones in Apac during the week of 18th February, 2016.

Parameter	Unit	Monitoring points						National Standards for potable water quality (water in supply)
		Waterworks		Water in Supply				
		Raw water	Final water	Hospital Road PSP	Area Office SP	Market Street PSP	Apac Upper Centre	
Codes		N973	N974	N975	N976	N977	N978	
pH	...	6.8	7.3	7.3	7.4	7.3	7.4	5.5 – 8.5
Turbidity	NTU	0.66	1.02	0.72	0.91	1.08	0.43	≤5
Colour	PtCo.	0	4	0	1	2	0	≤15
Iron	mg/L	0.18	0.11	0.13	0.15	0.14	0.12	≤0.300
Residue Aluminium	mg/L	N/A	N/A	N/A	N/A	N/A	N/A	≤0.20
Free chlorine	mg/L	N/A	0.72	0.43	0.36	0.32	0.41	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	360	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required