

ARUA AREA

Report date: 6th January-2016

Table: Water quality for Selected zones in Arua during the week of 31st December-2015

Parameter	Unit			Monitoring Points					National Standard For potable water quality (Water in Supply)
		Raw water	Treat ed Water	Water in Supply					
				Arua Hill Divisio n	River Oli Divisio n	Town Centre	Pajulu Sub county	Oluko Sub county	
CODE		AR01	AR02	AR04	AR05	AR06	AR07	AR08	
pH	...	7.7	7.6	7.4	7.5	7.5	7.6	7.4	5.5 – 8.5
Turbidity	NTU	33.86	2.07	3.08	3.01	3.52	2.18	3.22	≤5.00
Colour	PTU	205	10	10	10	10	10	10	≤15
Residual Aluminium	Mg/L	N/A	0.10	N/R	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	Mg/L	N/A	1.5	0.32	0.34	0.33	0.30	0.30	0.20 – 0.50
Faecal - Colifor	CFU/ 100 mL	2800	0	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required