



**NATIONAL WATER & SEWERAGE CORPORATION
WATER QUALITY MANAGEMENT DEPARTMENT**

ARUA AREA

Report date: 6th April 2016

Table: Water Quality for Selected zones in Arua during the week of 30th March, 2016.

Parameter	Unit	Monitoring points						National Standards for potable water (water in supply)
		Waterworks		Water in Supply				
		Raw water	Final water	Arua Hill Division	River Oli Division	Town Centre	Pajulu Sub-County	
Codes		N009	N010	N011	N012	N013	N014	
pH	7.45	7.21	7.20	7.04	7.24	7.00	5.5 – 8.5
Turbidity	NTU	77.8	3.01	3.00	2.86	3.10	3.04	≤5.00
Colour	PtCo.	800	10	10	10	10	10	≤15
Iron	mg/L	1.504	0.072	N/R	N/R	N/R	N/R	≤0.300
Residue Aluminium	mg/L	N/A	0.16	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	mg/L	N/A	1.20	0.20	0.30	0.30	0.30	0.20 – 0.50
Faecal-Coliform	CFU/100 mL	2200	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required