



**NATIONAL WATER & SEWERAGE CORPORATION  
WATER QUALITY MANAGEMENT DEPARTMENT**

**ARUA AREA**

**Report date:** 9<sup>th</sup> March 2016

**Table:** Water quality for Selected zones in Arua during the week of 3<sup>rd</sup> March, 2016.

Parameter	Unit	Monitoring points							National Standards for potable water (water in supply)
		Waterworks		Water in supply					
		Raw water	Treated Water	Arua Hill Division	River Oli Division	Town Centre	Pajulu S-County	Oluko Division	
Codes		N001	N002	N003	N004	N005	N006	N007	
pH	...	7.5	7.0	7.0	7.0	7.2	7.2	7.2	5.5 – 8.5
Turbidity	NTU	54.10	2.80	3.00	3.22	3.64	3.04	3.84	≤5.00
Colour	PTU	500	10	10	10	10	10	10	≤15
Iron	mg/L	0.325	0.12	0.16	0.14	0.12	0.13	0.15	≤0.300
Residual Aluminium	mg/L	N/A	0.12	NR	NR	NR	NR	NR	≤0.20
Free chlorine	mg/L	N.A.	1.20	0.30	0.30	0.20	0.30	0.20	0.20-0.50
Faecal - Coliforms	CFU/ 100 mL	1800	0	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required