

**ARUA AREA****Report date:** 26<sup>th</sup> September -2015**Table:** Water quality for Selected points in Arua during the week of 25<sup>th</sup> September, 2015

Parameter	Unit	Monitoring points							National standards for potable water quality
		Waterworks		Water in Supply					
		Raw water	Treated Water	Arua Hill Division	River Oli Division	Town Centre	Pajulu subcounty	Oluko subcounty	
CODES		N041	N042	N043	N044	N045	N046	N047	
pH	...	7.47	6.84	6.82	6.81	6.45	6.88	6.99	5.5 – 8.5
Turbidity	NTU	200	4.22	5.02	4.22	4.44	4.54	4.42	≤5.00
Colour	PTU	1450	20	20	20	20	20	20	≤15
Iron	mg/L	ND	ND	ND	ND	ND	ND	ND	≤0.30
Residue Aluminium	mg/L	N/A	0.2	N/R	N/R	N/R	N/R	N/R	≤0.20
Free Chlorine	mg/L	N/R	1.0	0.2	0.3	0.2	0.2	0.3	0.20 – 0.50
Faecal - Coliforms	CFU/ 100 ml	240	0	0	0	0	0	0	0

N/R-Not Required, N/D-Not Done