

**ARUA AREA****Report date:** 4<sup>th</sup> July -2015**Table:** Water quality for selected zones in Arua during the week of 1<sup>st</sup> July 2015

Parameter	Monitoring points								National Standard For potable water quality (Water in Supply)
	Unit	Raw Water	Treated Water	Water in Supply					
				Arua Hill Division	River Oli Division	Town Centre	Pajulu subcounty	Oluko subcounty	
pH	...	7.8	7.4	7.2	7.4	7.1	7.2	7.4	6.5 – 8.5
Turbidity	NTU	60	4.22	4.20	4.36	4.20	4.00	6.00	≤5.00
Colour	PTU	4400	10	10	10	10	10	10	≤15
Free chlorine	mg/l	N/A	1.00	0.20	0.20	0.20	0.40	0.40	0.20 – 0.50
Faecal - Coliforms	CFU/100 ml	1000	0	0	0	0	0	0	0