

## ARUA AREA

**Report date:** 8<sup>th</sup> December-2015

**Table:** Water quality for Selected zones in Arua during the week starting 3<sup>rd</sup> December-2015

Parameter	Unit			Monitoring Points					National Standard For potable water quality (Water in Supply)
		Raw water	Treat ed Water	Water in Supply					
				Arua Hill Divisio n	River Oli Divisio n	Town Centre	Pajulu S/Count y	Oluko S/Cou nty	
CODE		AR01	AR02	AR04	AR05	AR06	AR07	AR08	
pH	...	7.2	7.1	7.0	6.9	6.5	6.9	7.1	5.5 – 8.5
Turbidity	NTU	50.32	1.88	1.86	2.86	3.02	3.11	3.63	≤5.00
Colour	PTU	350	8	8	10	11	10	13	≤15
Iron	Mg/L	2.66	0.08	N/R	N/R	N/R	N/R	N/R	≤0.30
Residual Aluminium	Mg/L	N/A	0.2	N/R	N/R	N/R	N/R	N/R	≤0.2
Free chlorine	Mg/L	N/A.	1.30	0.30	0.28	0.30	0.40	0.30	0.20 – 0.50
Faecal - Colifor	CFU/ 100 mL	2560	0	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required