

ARUA AREA

Report date: 24th December-2015

Table: Water quality for Selected zones in Arua during the week of 17th December-2015

Parameter	Unit			Monitoring Points					National Standard For potable water quality (Water in Supply)
		Raw water	Treat ed Water	Water in Supply					
				Arua Hill Divisio n	River Oli Divisio n	Town Centre	Pajulu Subcou nty	Oluko Subco untly	
CODE		AR01	AR02	AR04	AR05	AR06	AR07	AR08	
pH	...	7.8	7.3	7.3	7.3	7.1	7.2	7.2	5.5 – 8.5
Turbidity	NTU	26.4	2.17	2.88	3.00	3.04	3.21	3.22	≤5.00
Colour	PTU	205	10	10	10	10	10	10	≤15
Residual Aluminium	Mg/L	N/A	0.2	N/R	N/R	N/R	N/R	N/R	≤0.2
Free chlorine	Mg/L	N/A	1.22	0.31	0.32	0.34	0.30	0.26	0.20 – 0.50
Faecal - Colifor	CFU/ 100 mL	300	0	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required