

ARUA AREA**Report date:** 29th June -2015**Table:** Water quality for selected Zones in Arua during the week of 22nd June 2015

Parameter	Monitoring points								National Standard For potable water quality (Water in Supply)
	Unit	Raw Water	Treated Water	Water in Supply					
				Arua Hill Division	River Oli Division	Town Centre	Pajulu Sub- County	Oluko Sub- County	
pH	...	8.0	7.1	7.2	7.2	7.4	7.1	7.4	6.5 – 8.5
Turbidity	NTU	355	3.60	4.60	3.88	4.80	3.60	4.50	≤5.00
Colour	PTU	2050	10	10	10	10	10	10	≤15
Free chlorine	mg/l	N/A	1.00	0.20	0.30	0.30	0.30	0.20	0.20 – 0.50
Faecal - Coliforms	CFU/ 100 ml	2200	0	0	0	0	0	0	0