

ARUA AREA**Report date:** 13th July -2015**Table:** Water quality for selected Zones in Arua during the week of 6th July 2015

Parameter	Monitoring points								National Standard For potable water quality (Water in Supply)
	Unit	Raw Water	Final Water	Water in Supply					
				Arua Hill Division	River Oli Division	Town Centre	Pajulu Sub-County	Oluko Sub-County	
pH	...	7.9	7.3	7.3	7.5	7.4	7.6	7.4	6.5 – 8.5
Turbidity	NTU	68	4.14	4.74	4.33	4.00	4.58	4.00	≤5.00
Colour	PTU	400	10	10	10	10	10	10	≤15
Free chlorine	mg/l	NA	1.20	0.20	0.20	0.40	0.40	0.20	0.20 – 0.50
Faecal - Coliforms	CFU/100 ml	1400	0	0	0	0	0	0	0