

BOMBO AREA**Report date:** 27th July -2015**Table:** Water quality for selected points in Bombo during the week of 20th July 2015

Parameter	Monitoring points						National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Treated Water	Water in Supply			
				Reservoir	Namaliga	Central Market	
pH	...	7.0	6.7	6.9	6.6	6.9	6.5 – 8.5
Turbidity	NTU	0.25	0.25	0.27	0.14	0.15	≤5.00
Colour	PTU	0	0	0	0	0	≤15
Free chlorine	mg/l	N/A	0.30	0.30	0.20	0.20	0.20 – 0.50
Faecal - Coliforms	CFU/ 100 ml	0	0	0	0	0	0