

BOMBO AREA

Report date: 13th July 2015

Table: Water quality for selected points in Bombo during the week of 6th July 2015

Parameter	Monitoring points						National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply			
				Bembe	Namaliga	Bombo central	
pH	...	5.93	6.12	6.54	6.63	6.92	5.5 – 8.5
Turbidity	NTU	0.254	0.253	0.271	0.140	0.15	≤5
Colour	PtCo.	0	0	0	0	0	≤15
Free chlorine	mg/L	NA	0.3	0.3	0.2	0.2	0.20 – 0.50
Faecal -Coliform	CFU/ 100 mL	0	0	0	0	0	0