



**NATIONAL WATER & SEWERAGE CORPORATION  
WATER QUALITY MANAGEMENT DEPARTMENT**

**BUSHENYI AREA**

**Report date:** 12<sup>th</sup> July 2016

**Table:** Water quality for Selected zones in **BUSHENYI** during the week ending 7<sup>th</sup> July 2016

Parameter				Monitoring points					National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply				
				Katungu Reservoir	Kantunda	Kizinda	Bushenyi Market	Kyamuhunga	
Codes		1093	1096	N097	N1098	N1098	N1099	N1100	
pH	....	6.0	6.2	7.8	7.9	7.9	8.0	7.9	5.5 – 8.5
Turbidity	NTU	15.10	1.80	2.10	2.00	1.80	2.30	1.90	≤5.00
Colour	PtCo.	307	4	4	0	3	8	4	≤15
Iron	Mg/l	2.695	0.072	N/R	N/R	N/R	N/R	N/R	≤0.300
Residue Aluminium	Mg/l	N/R	0.18	N/R	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	mg/L	N/R	1.20	0.51	0.31	0.22	0.26	0.28	0.20 – 0.50
Faecal - Coliform	CFU/100 mL	--	0	0	0	0	0	0	0