

BUSHENYI AREA**Report date:** 5th July -2015**Table:** Water quality for selected points in Bushenyi during the week of 1st July 2015

Parameter	Monitoring points								National Standard For potable water quality (Water in Supply)
	Unit	Raw Water	Final water	Water in Supply					
				Tank Hill Reservoirs	Bushenyi Town	Ishaka Town	Kizinda Trading Center	Rwentuha Town Board	
pH	...	6.10	5.66	5.81	5.93	6.31	6.07	5.91	5.5 – 8.5
Turbidity	NTU	8	1.00	0.00	1.00	1.00	1.00	1.00	≤5.00
Colour	PTU	698	3	6	7	5	8	5	≤15
Free chlorine	mg/l	N/A	1.12	0.41	0.28	0.25	0.24	0.26	0.20 – 0.50
Faecal - Coliforms	CFU/ 100 ml	206	0	0	0	0	0	0	0