

BUSHENYI AREA

Report date: 13th July -2015

Table: Water quality for selected zones in Bushenyi during the week of 6th July 2015

Parameter	Monitoring points							National Standard For potable water quality (Water in Supply)
	Unit	Raw Water Nyaruzin ga Wetland	Final water	Water in Supply				
				Bushenyi Town	Rwentuha	Kizinda Trading Center	Ishaka Town	
pH	...	5.5	6.8	6.3	6.1	6.1	6.3	6.5 – 8.5
Turbidity	NTU	4.2	0	0	0	1	0	≤5.00
Colour	PTU	746	11	4	7	10	4	≤15
Free chlorine	mg/l	NA	1.4	0.2	0.3	0.3	0.3	0.20 – 0.50
Faecal - Coliforms	CFU/ 100 ml	101	0	0	0	0	0	0