

BUSHENYI AREA**Report date:** 24th December -2015**Table:** Water quality for Selected zones in **Bushenyi** during the week of 17th December 2015

Parameter				Monitoring points				National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply			
				Tororo North	Tororo West	Tororo South	Malaba Territory	
Codes		N070	N071	N072	N073	N074	N075	
pH	6.0	5.8	5.9	5.8	5.9	5.8	5.5 – 8.5
Turbidity	NTU	20.60	1.70	2.20	2.60	1.80	1.40	≤5.00
Colour	PtCo.	710	7	9	12	13	4	≤15
Iron	Mg/L	23.60	0.28	N/R	N/R	N/R	N/R	≤0.30
Residue Aluminium	Mg/L	NA	0.16	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	Mg/L	NA	1.20	0.48	0.22	0.26	0.24	0.20 – 0.50
Faecal – Coliform	CFU/ 100 mL	210	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required