

BUSHENYI AREA**Report date:** 27th July -2015**Table:** Water quality for selected points in Bushenyi during the week of 20th July 2015

Parameter	Monitoring points							National Standard For potable water quality (Water in Supply)
	Unit	Raw Water Nyaruzin ga Wetland	Final water	Water in Supply				
				Kanungu Reservoir	Kizinda Town Centre	Butaare Center	Rwentuha Town Board	
pH	...	5.6	5.6	6.0	6.1	5.8	6.0	6.5 – 8.5
Turbidity	NTU	9.61	0.00	0.00	1.00	0.00	1.00	≤5.00
Colour	PTU	553	0	7	4	3	7	≤15
Free chlorine	mg/l	N/A	1.49	0.36	0.25	0.24	0.26	0.20 – 0.50
Faecal - Coliforms	CFU/ 100 ml	133	0	0	0	0	0	0