

BUSHENYI AREA**Report date:** 25rd November-2015**Table:** Water quality for Selected zones in Bushenyi during the week of 19th November 2015

Parameter				Monitoring points				National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply			
				Katungu Reservoir	Kizinda Center	Basajja Center	Ishaka Market	
Codes		N052	N053	N054	N055	N056	N057	
pH	6.5	6.0	5.9	5.7	6.1	6.3	5.5 – 8.5
Turbidity	NTU	12.67	1.90	2.00	2.00	1.00	2.00	≤5.00
Colour	PtCo.	1041	9	8	11	6	4	≤15
Iron	Mg/l	7.300	0.200	N/R	N/R	N/R	N/R	≤0.300
Residue Aluminium	Mg/l	N/A	0.27	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	mg/L	NA	0.85	0.20	0.10	0.20	0.20	0.20 – 0.50
Faecal – Coliform	CFU/ 100 mL	110	0	0	0	0	0	0

N/A: Not applicable, N/R: Not Required