

## BUSHENYI AREA

**Report Date:** 22nd September 2015

**Table:** Water Quality for Selected Zones in Bushenyi during the week of 18<sup>th</sup> September 2015

Parameter				Monitoring points					National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply					
				Katungu	Ishaka-	Nyakabirizi	Rwemirokorora	Ncucumo	
CODES		BUS14	BUS15	BUS16	BUS17	BUS18	BUS19	BUS20	
pH	...	5.8	5.7	5.8	5.7	5.7	5.8	5.8	5.5 – 8.5
Turbidity	NTU	28.3	2.0	2.0	2.0	1.0	2.0	1.0	≤5
Colour	PtCo.	1490	10	7	8	12	5	10	≤15
Iron Total	Mg/L	10.55	0.14	NR	NR	NR	NR	NR	<0.300
Aluminium Residuals	Mg/L	NA	0.20	NR	NR	NR	NR	NR	<0.20
Free chlorine	mg/L	NA	0.80	0.48	0.24	0.26	0.22	0.24	0.20 – 0.50
Faecal -Coliform	CFU/100 mL	360	0	0	0	0	0	0	0