

**BWEYALE AREA****Report date:** 13<sup>th</sup> January-2016**Table:** Water quality for Selected zones in Bweyale during the week of 7<sup>th</sup> January-2016.

Parameter	Monitoring points								National Standard For potable water quality (Water in Supply)
	Unit	Raw water(B /H bagdad)	Final water	Water in Supply					
				Reservo ir Bagdad	Panya doli	Rift valley	Siriba p/s	Katurikire	
pH	....	7.2	7.2	7.1	7.2	7.3	7.2	7.1	5.5 – 8.5
Turbidity	NTU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	≤5.00
Colour	PtCo.	16	2	0	1	0	0	0	≤15
Iron	Mg/L	0.322	0.198	N/A	N/A	N/A	N/A	N/A	≤0.300
Residue Aluminium	Mg/L	N/A	N/A	N/A	N/A	N/A	N/A	N/A	≤0.20
Free chlorine	Mg/L	N/A	0.50	0.50	0.20	0.40	0.20	0.20	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	0	0	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required