



# NATIONAL WATER & SEWERAGE CORPORATION

## WATER QUALITY MANAGEMENT DEPARTMENT

### BWEYALE AREA

**Report Date:** 21<sup>st</sup> April 2016

**Table:** Water Quality for Selected Zones in Nebbi during the week starting 14<sup>th</sup> April, 2016

Parameter	Unit	Raw water	Final water	Monitoring points				National Standard For potable water quality (Water in Supply)
				PSP Town	Engineers Tap	Community health service	Kigara agara	
CODE		N016	N017	N018	N019	N020	N021	
pH	....	7.3	7.2	7.2	7.1	7.1	7.2	5.5 – 8.5
Turbidity	NTU	0.60	0.00	0.00	0.00	0.00	0.00	≤5.00
Colour	PtCo.	9	0	0	0	0	0	≤15
Iron	Mg/l	0.8	0.15	N/A	N/A	N/A	N/A	≤0.30
Residue Aluminium	Mg/l	NA	NA	N/A	N/A	N/A	N/A	≤0.20
Free chlorine	Mg/L	N/A	0.80	0.30	0.20	0.20	0.20	0.20 – 0.50
Faecal Coliform	CFU/100 mL	0	0	0	0	0	0	0

NA: Not applicable, NR: Not Reported