



NATIONAL WATER & SEWERAGE CORPORATION
WATER QUALITY MANAGEMENT DEPARTMENT
BWEYALE WATER AREA

Report date: 30th June-2016

Table: Water quality for Selected zones in Bweyale during the week of 24th June 2016

Parameter				Monitoring points				National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply			
				Panyandoli	Rift valley	Siriba	Katurikire	
CODE		N100	N101	N102	N103	N104	N105	
pH	7.2	7.2	7.0	7.1	7.2	7.2	5.5 – 8.5
Turbidity	NTU	0.00	0.00	0.00	0.00	0.00	0.00	≤5.00
Colour	PtCo.	0	0	0	0	0	5	≤15
Iron	Mg/l	0.05	0.03	N/R	N/R	N/R	N/R	≤0.300
Residue Aluminium	Mg/l	N/A	NR	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	mg/L	NA	0.43	0.20	0.20	0.20	0.21	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	0	0	0	0	0	0	0