



**NATIONAL WATER & SEWERAGE CORPORATION
WATER QUALITY MANAGEMENT DEPARTMENT**

BWEYALE AREA

Report date: 11th May 2016

Table: Water quality for Selected zones in **BWEYALE** during the week of 5th May. 2016

Parameter				Monitoring points				National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply			
				Panyand oli	Rift valley	Siriba	katurikire	
Codes		N2400	N2401	N2402	N2403	N24044	N24045	
pH	7.3	7.2	7.0	7.2	7.3	7.3	5.5 – 8.5
Turbidity	NTU	5.00	0.00	0.00	0.00	0.00	0.00	≤5.00
Colour	PtCo.	16	0	0	0	1	0	≤15
Iron	Mg/l	0.500	0.020	N/A	N/A	N/A	N/A	≤0.300
Residue Aluminium	Mg/l	N/A	N/A	N/A	N/A	N/A	N/A	≤0.20
Free chlorine	Mg/L	N/A	0.60	0.30	0.20	0.20	0.40	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	1	0	0	0	0	0	0