

**BWEYALE AREA****Report date:** 15<sup>th</sup> September -2015**Table:** Water quality for Selected points in Bweyale during the week of 11<sup>th</sup> September 2015

Parameter				Monitoring points			National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply			
				Rift Valley Bweyale	Bweyale Lucor allied	Mushoro's shop	
Codes		N4351	N4352	N4353	N4354	N4355	
pH	....	7.4	8.7	8.1	8.0	7.8	5.5 – 8.5
Turbidity	NTU	0.35	0.28	0.30	0.25	0.29	≤5.00
Colour	PtCo.	1	0	0	0	0	≤15
Iron	Mg/l	0.79	0.04	0.02	0.01	0.00	≤0.30
Residue Aluminium	Mg/l	N/A	0.00	0.00	0.00	0.00	≤0.20
Free chlorine	mg/L	N/A	1.70	0.37	0.35	0.39	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	4	0	0	0	0	0

N/A – Not applicable