



NATIONAL WATER & SEWERAGE CORPORATION
WATER QUALITY MANAGEMENT DEPARTMENT

ENTEBBE AREA

Report date: 23rd June -2016

Table: Water quality for Selected points in Entebbe during the week starting 16th June 2016

Parameter				Monitoring points				National Standard
	Unit	Raw water	Final water		Water in Supply			For potable water quality (Water in Supply)
				Akright	kajjansi	Bwebajja	Kitiiko	
CODE		N071	N072	N074	N075	N076	N077	
pH	8.2	7.5	7.5	7.6	7.9	7.5	5.5 – 8.5
Turbidity	NTU	4.30	0.50	0.37	0.72	0.79	0.77	≤5.00
Colour	PtCo.	44	2	0	1	3	5	≤15
Iron	Mg/l	0.100	0.000	N/R	N/R	N/R	N/R	≤0.300
Residue Aluminium	Mg/l	N/R	0.00	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	mg/L	N/R	0.70	0.24	0.25	0.28	0.24	0.20 – 0.50
Faecal-Coliform	CFU/100 mL	0	0	0	0	0	0	0