



**NATIONAL WATER & SEWERAGE CORPORATION
WATER QUALITY MANAGEMENT DEPARTMENT**

ENTEBBE AREA

Report date: 14th July -2016

Table: Water quality for Selected points in Entebbe during the week starting 11th July 2016

Parameter				Monitoring points				National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply			
				Akright	Kajjansi	Namulanda	Lweza	
CODE		N055	N056	N057	N058	N059	N060	
pH	8.0	7.4	7.9	7.6	7.4	7.4	5.5 – 8.5
Turbidity	NTU	4.90	0.40	0.96	1.31	1.20	1.47	≤5.00
Colour	PtCo.	44.7	0	4	2	3	4	≤15
Iron	Mg/l	0.01	0.000	N/R	N/R	N/R	N/R	≤0.300
Residue Aluminium	Mg/l	N/R	0.00	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	mg/L	N/R	0.90	0.22	0.20	0.21	0.2	0.20 – 0.50
Faecal-Coliform	CFU/ 100 mL	0	0	0	0	0	0	0