



NATIONAL WATER & SEWERAGE CORPORATION

WATER QUALITY MANAGEMENT DEPARTMENT

ENTEBBE AREA

Report date: 21st April 2016

Table: Water quality for Selected points in Entebbe during the week starting 14th April 2016

Parameter				Monitoring points				National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply				
				Airport canteen	Airport control tower	Merry land	Imperial Resort Hotel	
CODE		N1106	N1107	N1108	N1109	N1110	N1112	
pH	8.4	7.7	7.77.5	7.7	7.5	7.7	5.5 – 8.5
Turbidity	NTU	5.65	0.19	0.28	0.21	0.20	0.27	≤5.00
Colour	PtCo.	47	0	0	2	0	1	≤15
Iron	Mg/l	0.43	0.01	N/A	N/A	N/A	N/A	≤0.30
Residue Aluminium	Mg/l	N/A	N/R	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	Mg/L	N/A	0.40	0.30	0.20	0.20	0.30	0.20 – 0.50
Faecal- Coliform	CFU/ 100 mL	0	0	0	0	0	0	0

NA: Not applicable, N/R: Not Reported