



**NATIONAL WATER & SEWERAGE CORPORATION
WATER QUALITY MANAGEMENT DEPARTMENT**

ENTEBBE AREA

Report date: 30th June -2016

Table: Water quality for Selected points in Entebbe during the week starting 23rd June 2016

Parameter				Monitoring points				National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply			
				Town centre	Central Mkt	kayond o	NWSC rea office	
CODE		N3036	N3037	N3043	N3044	N3045	N3046	
pH	8.4	8.0	8.1	8.0	8.2	8.5	5.5 – 8.5
Turbidity	NTU	2.55	0.48	0.43	0.56	0.49	0.34	≤5.00
Colour	PtCo.	24	0	0	0	0	0	≤15
Iron	Mg/l	0.050	0.040	N/R	N/R	N/R	N/R	≤0.300
Residue Aluminium	Mg/l	N/R	0.024	0.005	N/R	N/R	N/R	≤0.20
Free chlorine	mg/L	N/R	0.73	0.25	0.24	0.25	0.24	0.20 – 0.50
Faecal- Coliform	CFU/ 100 mL	0	0	0	0	0	0	0