



**NATIONAL WATER & SEWERAGE CORPORATION
WATER QUALITY MANAGEMENT DEPARTMENT**

ENTEBBE AREA

Report date: 15th September -2016

Table: Water quality for Selected points in Entebbe during the week starting 8th September **2016**

Parameter				Monitoring points				National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply			
				Kabale	Bendegere	Kasenyi	Bwebajja	
CODE		N206	N207	N208	N209	N210	N211	
pH	7.8	7.7	7.4	7.7	7.4	7.3	5.5 – 8.5
Turbidity	NTU	4.70	0.66	0.64	0.81	0.71	0.71	≤5.00
Colour	PtCo.	47	2	3	4	0	1	≤15
Iron	Mg/l	0.030	0.000	N/R	N/R	N/R	N/R	≤0.300
Residue Aluminium	Mg/l	N/R	0.00	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	mg/L	N/R	1.00	0.33	0.21	0.40	0.32	0.20 – 0.50
Faecal- Coliform	CFU/ 100 mL	15	0	0	0	0	0	0