



NATIONAL WATER & SEWERAGE CORPORATION

WATER QUALITY MANAGEMENT DEPARTMENT

ENTEBBE AREA

Report date: 25th January-2016

Table: Water quality for Selected zones in Entebbe during the week starting 18th January-2016.

Parameter	Monitoring points								National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply					
				Nakiwogo	Queen's road	Geological	Anderita	Kabale	
CODES		N121	N122	N123	N124	N125	N126	N127	
pH	8.2	7.6	7.1	7.2	6.7	7.0	7.2	5.5 – 8.5
Turbidity	NTU	3.37	0.20	0.54	0.25	0.36	0.54	0.28	≤5.00
Colour	PtCo.	33	0	5	3	0	6	2	≤15
Iron	Mg/L	NA	0.00	N/A	N/A	N/A	N/A	N/A	≤0.300
Residue Aluminium	Mg/L	N/A	N/A	N/A	N/A	N/A	N/A	N/A	≤0.20
Free chlorine	Mg/L	N/A	0.71	0.20	0.40	0.30	0.20	0.30	0.20 – 0.50
Faecal Coliform	CFU/100 mL	2	0	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required