



# NATIONAL WATER & SEWERAGE CORPORATION

## WATER QUALITY MANAGEMENT DEPARTMENT

### ENTEBBE AREA

**Report date:** 21<sup>st</sup> January-2016

**Table:** Water quality for Selected zones in Entebbe during the week of 11<sup>th</sup> January-2016.

Parameter	Monitoring points								National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply					
				Airport canteen	Airport control tower	Merry land High Sch	Imperial Resort Hotel	Wild Life Zoo	
CODES		N107	N108	N109	N110	N111	N112	N113	
pH	....	7.8	7.3	6.9	7.2	7.4	7.6	7.7	5.5 – 8.5
Turbidity	NTU	3.20	0.20	0.00	0.00	0.00	0.00	0.00	≤5.00
Colour	PtCo.	30	0	0	1	0	0	0	≤15
Iron	Mg/L	0.02	0.00	N/A	N/A	N/A	N/A	N/A	≤0.300
Residue Aluminium	Mg/L	N/A	N/A	N/A	N/A	N/A	N/A	N/A	≤0.20
Free chlorine	Mg/L	N/A	0.81	0.30	0.40	0.20	0.20	0.30	0.20 – 0.50
Faecal Coliform	CFU/100 mL	4	0	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required