



**NATIONAL WATER & SEWERAGE CORPORATION
WATER QUALITY MANAGEMENT DEPARTMENT**

ENTEBBE AREA

Report date: 24th February 2016

Table: Water quality for Selected zones in **Entebbe** during the week of 18th February. **2016**

Parameter				Monitoring points				National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply			
				Airport Control tower	Imperial ResorH otel	Geological	Anderita	
Codes		N210	N211	N212	N213	N214	N215	
pH	8.3	7.7	7.3	7.9	7.5	7.2	5.5 – 8.5
Turbidity	NTU	0.8	0.2	0.37	0.42	0.31	0.24	≤5.00
Colour	PtCo.	34	0	0	1	0	0	≤15
Iron	Mg/l	0.06	0.00	N/A	N/A	N/A	N/A	≤0.300
Residue Aluminium	Mg/l	NA	NA	N/A	N/A	N/A	N/A	≤0.20
Free chlorine	Mg/L	N/A	0.80	0.20	0.30	0.30	0.20	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	4	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required