

ENTEBBE AREA**Report date:** 14th December -2015**Table:** Water quality for Selected points in Entebbe during the week starting 10th December 2015

Parameter				Monitoring points					National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply				
				Airport Canteen	Imperial Resort	Wildlif e Zoo	Bwebaj ja	Kajjansi T/C	
CODE		N033	N034	N035	N036	N037	N038	N039	
pH	7.6	7.3	7.4	7.5	7.3	7.5	7.5	5.5 – 8.5
Turbidity	NTU	2.82	0.14	0.40	0.30	0.40	0.30	0.60	≤5.00
Colour	PtCo.	32	0	0	0	1	0	3	≤15
Iron	Mg/L	0.03	0.00	0.00	0.00	0.00	0.00	0.00	≤0.30
Residue Aluminium	Mg/L	N/A	N/A	N/A	N/A	N/A	N/A	N/A	≤0.20
Free chlorine	Mg/L	N/A	0.60	0.30	0.20	0.30	0.30	0.20	0.20 – 0.50
Faecal- Coliform	CFU/ 100 mL	2	0	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required