

ENTEBBE AREA**Report date:** 25th November -2015**Table:** Water quality for Selected points in Entebbe during the week starting 19th November 2015

Parameter	Monitoring points									National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water Old plant	Final water New plant	Water in Supply					
					Kabale Stand Pipe	Bende gere	Kasen yi	Kajjan si T/C	Kitiko- Mutun go	
CODE		N01	N04	N037	N022	N023	N024	N032	N031	
pH	7.47	7.34	7.43	7.1	7.4	7.2	7.5	7.6	5.5 – 8.5
Turbidity	NTU	2.47	0.24	0.94	0.50	0.40	0.10	0.20	0.60	≤5.00
Colour	PtCo.	23	0	16	0	1	0	1	4	≤15
Iron	Mg/l	0.04	0.00	0.02	NR	NR	NR	NR	NR	≤0.300
Residue Al	Mg/l	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	≤0.20
Free chlorine	Mg/L	N/A	0.94	0.40	0.6	0.3	0.4	0.2	0.1	0.20 – 0.50
Faecal- Coliform	CFU/ 100 mL	1	0	0	0	0	0	0	0	0

N/A: Not applicable, N/R: Not Required