

ENTEBBE AREA**Report date:** 2nd November -2015**Table:** Water quality for Selected points in Entebbe during the week starting 26th October 2015

Parameter				Monitoring points				National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply				
				Airport canteen	Imperial resort	Wildlife Zoo	Bendegere	
CODE		N043	N044	N045	N046	N047	N048	
pH	7.6	7.4	7.6	7.2	7.4	7.3	5.5 – 8.5
Turbidity	NTU	2.83	0.13	0.40	0.10	0.50	0.30	≤5.00
Colour	PtCo.	34	0	1	0	1	3	≤15
Iron	Mg/l	0.01	0.000	N/R	N/R	N/R	N/R	≤0.300
Residue Aluminium	Mg/l	NA	0.00	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	Mg/L	NA	0.93	0.50	0.20	0.60	0.30	0.20 – 0.50
Faecal- Coliform	CFU/ 100 mL	32	0	0	0	0	0	0

NA: Not applicable, N/R: Not Reported