

ENTEBBE AREA**Report date:** 8th December -2015**Table:** Water quality for Selected points in Entebbe during the week starting 3rd December 2015

Parameter				Monitoring points					National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply					
				Akright Tank	Kajjansi Tank	Bweba jja	Kitiko- Mutun go	Kajjansi T/C	
CODE		N001	N004	N010	N011	N026	N031	N032	
pH	7.27	6.93	7.2	7.3	6.9	7.4	7.5	5.5 – 8.5
Turbidity	NTU	2.53	0.17	0.70	1.00	0.80	0.50	0.30	≤5.00
Colour	PtCo.	26	0	8	11	6	1	0	≤15
Iron	Mg/l	0.08	0.00	N/A	N/A	N/A	N/A	N/A	≤0.30
Residue Aluminium	Mg/l	N/A	N/A	N/A	N/A	N/A	N/A	N/A	≤0.20
Free chlorine	Mg/L	N/A	0.60	0.40	0.40	0.40	0.20	0.20	0.20 – 0.50
Faecal- Coliform	CFU/ 100 mL	0	0	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required