

ENTEBBE AREA**Report date:** 16th November -2015**Table:** Water quality for Selected points in Entebbe during the week starting 12th November 2015

Parameter				Monitoring points				National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply				
				Airport canteen	Imperial resort	Geological	Anderita	
CODE		N049	N050	N051	N052	N053	N054	
pH	7.5	7.3	7.9	7.2	8.1	7.9	5.5 – 8.5
Turbidity	NTU	3.43	0.21	0.30	0.90	0.90	0.30	≤5.00
Colour	PtCo.	29	0	0	4	6	0	≤15
Iron	Mg/l	0.06	0.00	N/R	N/R	N/R	N/R	≤0.300
Residue Aluminium	Mg/l	NA	N/A	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	Mg/L	NA	0.89	0.30	0.20	0.50	0.50	0.20 – 0.50
Faecal- Coliform	CFU/ 100 mL	43	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required