

ENTEBBE AREA**Report date:** 9th September -2015**Table:** Water quality for Selected points in Entebbe during the week of 3rd September 2015

Parameter				Monitoring points					National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply				
				Akright Tank	Kajjansi Tank	Bwebajj a	Kitiko- Mutungo	Kajjansi T.C	
Codes		N001	N002	N003	N004	N005	N006	N007	
pH	7.9	7.6	7.8	7.9	7.5	7.7	7.9	5.5 – 8.5
Turbidity	NTU	4.89	0.27	0.40	0.20	0.50	0.30	0.20	≤5.00
Colour	PtCo.	48	0.29	2	0	3	2	3	≤15
Iron	Mg/l	0.190	0.00	0.000	0.000	0.000	0.000	0.000	≤0.300
Residue Aluminium	Mg/l	-	0.00	0.00	0.00	0.00	0.00	0.00	≤0.20
Free chlorine	mg/L	N/A	0.81	0.30	0.20	0.30	0.10	0.10	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	18	0	0	0	0	0	0	0