

ENTEBBE AREA**Report date:** 15th September -2015**Table:** Water quality for Selected points in Entebbe during the week of 11th September 2015

Parameter				Monitoring points					National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply				
				Marryl and H.Sch.	Airport Control Tower	Airport Canteen	Queen's Road	Wild life	
Sample No		N4311	N4312	N4318	N4319	N4320	N4321	N4322	
pH	7.5	7.6	7.6	8.0	7.5	7.7	7.8	5.5 – 8.5
Turbidity	NTU	2.41	0.95	0.19	0.41	0.45	0.52	0.20	≤5.00
Colour	PtCo.	29	0	0	0	0	0	0	≤15
Iron	Mg/l	0.20	0.00	0.00	0.00	0.00	0.00	0.00	≤0.300
Residue Aluminium	Mg/l	N/A	0.00	0.00	0.00	0.00	0.00	0.00	≤0.20
Free chlorine	mg/L	N/A	0.81	0.30	0.20	0.30	0.10	0.10	0.20 – 0.50
Faecal- Coliform	CFU/ 100 mL	280	0	0	0	0	0	0	0

N/A – Not applicable