

**ENTEBBE AREA****Report date:** 22<sup>nd</sup> June 2015**Table:** Water quality for selected points in Entebbe during the week of 15<sup>th</sup> June 2015

| Parameter            | Monitoring points |              |                |                    |                                 |                  |                  |                     | National Standard<br>For potable water<br>quality<br>(Water in Supply) |
|----------------------|-------------------|--------------|----------------|--------------------|---------------------------------|------------------|------------------|---------------------|--|
|                      | Unit              | Raw<br>water | Final<br>water | Water in Supply    |                                 |                  |                  |                     |  |
|                      |                   |              |                | Airport<br>Canteen | Airport<br>Contro<br>l<br>Tower | Merryland<br>H/S | Queen`<br>s Road | Wild<br>Life<br>Zoo |  |
| pH                   | ...               | 7.70         | 7.40           | 7.40               | 7.40                            | 7.50             | 7.30             | 7.40                | 5.5 – 8.5  |
| Turbidity            | NTU               | 3.0          | 0.3            | 0.1                | 0.1                             | 0.4              | 0.3              | 0.3                 | ≤5   |
| Colour               | PtCo.             | 32.3         | 0              | 0                  | 0                               | 4                | 0                | 1                   | ≤15  |
| Free chlorine        | mg/L              | N/A          | 0.8            | 0.2                | 0.2                             | 0.1              | 0.3              | 0.2                 | 0.20 – 0.50  |
| Faecal -<br>Coliform | CFU/ 100 mL       | 6            | 0              | 0                  | 0                               | 0                | 0                | 0                   | 0  |