

ENTEBBE AREA**Report date:** 24th December -2015**Table:** Water quality for Selected points in Entebbe during the week starting 17th December 2015

Parameter				Monitoring points					National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply				
				Nakiwogo	Busamba ga	Garuga	Kakind u	Kawuku	
CODE		N040	N041	N042	N043	N044	N045	N046	
pH	7.4	7.4	7.6	7.4	7.6	7.5	7.4	5.5 – 8.5
Turbidity	NTU	3.42	0.12	0.3	0.30	0.6	0.2	0.4	≤5.00
Colour	PtCo.	34	0	0	0	1	0	1	≤15
Iron	Mg/l	0.03	0.00	0.00	0.00	0.00	0.00	0.00	≤0.30
Residue Aluminium	Mg/l	N/A	N/A	N/A	N/A	N/A	N/A	N/A	≤0.20
Free chlorine	Mg/L	N/A	0.90	0.40	0.3	0.2	0.30	0.20	0.20 – 0.50
Faecal- Coliform	CFU/ 100 mL	41	0	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required