

ENTEBBE AREA**Report date:** 29th June 2015**Table:** Water quality for different zones in Entebbe during the week of 22nd June 2015

Parameter	Monitoring points							National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply				
				Entebbe North	Entebbe West	Entebbe South	Entebbe East Wild Life Zoo	
pH	...	7.5	7.00	7.0	6.9	7.02	7.00	5.5 – 8.5
Turbidity	NTU	2.52	0.14	0.25	0.3	0.2	0.1	≤5
Colour	PtCo.	27.60	0.0	5	2	1	0	≤15
Free chlorine	mg/L	N/A	0.70	0.2	0.2	0.1	0.1	0.20 – 0.50
Faecal -Coliform	CFU/ 100 mL	8	0	0	0	0	0	0